

Dear Mr. Meyer,

To ensure the health and safety of all DOI building occupants, the GSA Modernization team has had an industrial hygiene contractor (SaLUT, Inc.)

conduct air monitoring for both asbestos and lead based paint. All air sampling results collected in occupied areas were within regulatory guidelines (See attached SaLUT report summaries).

(See attached file: February Report.pdf)

In addition to the routine asbestos and lead based paint air monitoring, the GSA Safety, Environment, & Fire Protection Branch has been conducting

weekly proactive Total Volatile Organic Compound (TVOC) and Particulate air

screenings within the DOI-Main Building. These screenings are used to monitor and help improve the engineering controls utilized by the Modernization Contractor (Grunley), and to minimize the occurrence of construction odors/dust in occupied areas. Screening results indicate that

all parameters tested were within regulatory and comfort guidelines.

Copies of all GSA weekly air sampling, as well as, SaLUT's daily air sampling have been forwarded to your office.

Please contact me if you have any questions.

James Hodges, CHMM
Industrial Hygienist
GSA Safety, Environment, and Fire Protection Branch
301 7th Street, SW
Room 2080
Washington, DC 20407
(O) 202-708-5253
(C) 202-369-3059
(F) 202-708-6618

**INDUSTRIAL HYGIENE SERVICES
AT THE
DEPARTMENT OF INTERIOR MAIN MODERNIZATION PROJECT
19TH AND C ST., NW
IN
WASHINGTON, DC**

Submitted to:

GSA NCR Service Del. Support
Safety, Env. & Fire
7th & D Sts., SW, Room 2080
Washington, DC 20407

Attention: Mr. James Hodges

Prepared by:



Kathleen Walsh
Project Manager

Submitted by:

Soil and Land Use Technology, Inc.
4740 Corridor Place, Suite E
Beltsville, Maryland 20705

For the period of:

January 29 - February 23, 2007

TABLE OF CONTENTS

1. PROJECT SUMMARY..... 1

2. ASBESTOS ABATEMENT ACTIVITIES 1

3. INSPECTIONS AND SAMPLING 1

4. EVALUATIONS AND CONCLUSIONS 1

APPENDICES

A DAILY SUMMARIES - AMBIENT AIR SAMPLING

B AMBIENT AIR SAMPLING ANALYSIS - PCM ANALYSIS

C DAILY SUMMARIES - ASBESTOS AND LEAD ABATEMENT

D ASBESTOS ABATEMENT AIR ANALYSIS - PCM & TEM ANALYSIS

E LEAD ABATEMENT AIR ANALYSIS - FLAME ATOMIC ABSORPTION
ANALYSIS

F ASBESTOS BULK SAMPLE ANALYSIS - POLARIZED LIGHT MICROSCOPY

1. PROJECT SUMMARY

Soil and Land Use Technology, Inc. (SaLUT) was contracted by the General Services Administration to perform Industrial Hygiene monitoring during the renovation and demolition activities associated with the Department of Interior Main Modernization project located at 19th and C St., NW in Washington, DC. Mr. Thilina Sumanaweera, Mr. Walter Gonzalez, and Mr. Juan Giron performed the inspections and sampling during this time.

Work commenced on October 23, 2004 and continues to date. This report covers the period from January 29 to February 23, 2007. Goel Construction is the contractor conducting the demolition and abatement that involves lead-based painted building components and the removal of asbestos containing materials (ACM). Basic Industries is the contractor performing lead-based paint removal.

2. ASBESTOS AND LEAD ABATEMENT ACTIVITIES

Abatement of asbestos containing pipe and duct insulation continues on 2nd through 7th Floors. One bulk sample was taken on the 7th Floor East Wing. Results are attached. From January 29 - February 23, ambient air sampling continued to be conducted in the corridors of the occupied areas.

3. INSPECTION AND SAMPLING

SaLUT's Industrial Hygienist, who has successfully completed the NIOSH 582 or equivalent course, analyzed all asbestos air samples on site. The air analysis results are enclosed in the Appendix B of this report. The criterion for occupancy is less than 0.01 fibers per cubic centimeter (0.01f/cc).

Ambient air samples were collected throughout the building every day and remained within guidelines.

4. EVALUATIONS AND CONCLUSIONS

Ambient air sampling documentation includes: Daily Summaries (Appendix A), PCM Air Sample Data Sheets (Appendix B). Asbestos and lead abatement monitoring includes: Daily Summaries (Appendix C), PCM and TEM Data Sheets and Results (Appendix D), and Flame Atomic Absorption Analysis (Appendix E). This project continues to date.