

**Daily Engineering Control Verification Sampling  
General Services Administration  
Department of the Interior Modernization Program  
1849 C Street NW, Washington, DC**

**Week ending: 7/03/2008**

Note 1: TVOC = Total Volatile Organic Compounds, which is the total concentration of any volatile organic compounds that may be present. Volatile organic compounds are organic chemicals that have a high vapor pressure and easily form vapors at normal temperature. While there is currently no Permissible Exposure Limit (PEL) for TVOCs, an action level of 1.3 parts per million (ppm) has been established for this project based on best available research.

Note 2: OSHA Total and Respirable Particulate PEL = 15.0 milligrams per cubic meter of air (mg/m<sup>3</sup>) for total particulates, 5.0 mg/m<sup>3</sup> for respirable particulates.

**Friday: 6/27/2008**

Floor	Location	Time	Total Particulates (mg/m <sup>3</sup> )	TVOC (ppm)	Comments
7	Along main corridor between barricades	945	0.037	0.0	
6	Along main corridor between barricades	947	0.036	0.0	
5	Along main corridor between barricades	949	0.033	0.0	
4	Along main corridor between barricades	953	0.039	0.0	
3	Along main corridor between barricades	955	0.044	0.0	
2	Along main corridor between barricades	956	0.045	0.0	
1	Along main corridor between barricades	958	0.062	0.0	
B	Along main corridor between barricades	1000	0.052	0.0	
5	Wing 3 rm 5339-5361	951	0.045	0.0	

**Monday: 6/30/2008**

Floor	Location	Time	Total Particulates (mg/m <sup>3</sup> )	TVOC (ppm)	Comments
7	Along main corridor between barricades				
6	Along main corridor between barricades				
5	Along main corridor between barricades				IH on Vacation  No testing
4	Along main corridor between barricades				
3	Along main corridor between barricades				
2	Along main corridor between barricades				
1	Along main corridor between barricades				
B	Along main corridor between barricades				

Tuesday: 7/01/2008

Floor	Location	Time	Total Particulates (mg/m <sup>3</sup> )	TVOC (ppm)	Comments
7	Along main corridor between barricades	1345	0.033	0.0	
6	Along main corridor between barricades	1347	0.018	0.0	
5	Along main corridor between barricades	1349	0.012	0.0	
4	Along main corridor between barricades	1353	0.021	0.0	
3	Along main corridor between barricades	1355	0.026	0.0	
2	Along main corridor between barricades	1357	0.033	0.0	
1	Along main corridor between barricades	1359	0.031	0.0	
B	Along main corridor between barricades	1400	0.043	0.0	
4	Wing 3 rm 4339-4361	1351	0.029	0.0	

Wednesday: 7/02/2008

Floor	Location	Time	Total Particulates (mg/m <sup>3</sup> )	TVOC (ppm)	Comments
7	Along main corridor between barricades	935	0.035	0.0	
6	Along main corridor between barricades	937	0.024	0.0	
5	Along main corridor between barricades	941	0.023	0.0	
4	Along main corridor between barricades	943	0.031	0.0	
3	Along main corridor between barricades	945	0.035	0.0	
2	Along main corridor between barricades	947	0.036	0.0	
1	Along main corridor between barricades	949	0.040	0.0	
B	Along main corridor between barricades	950	0.051	0.0	
6	Wing 5 rm 6510-6531	939	0.031	0.0	

Thursday: 7/03/2008


Floor	Location	Time	Total Particulates (mg/m <sup>3</sup> )	TVOC (ppm)	Comments
7	Along main corridor between barricades	1052	0.040	0.0	
6	Along main corridor between barricades	1054	0.040	0.0	
5	Along main corridor between barricades	1056	0.028	0.0	
4	Along main corridor between barricades	1058	0.036	0.0	
3	Along main corridor between barricades	1100	0.056	0.0	
2	Along main corridor between barricades	1102	0.047	0.0	
1	Along main corridor between barricades	1104	0.043	0.0	
B	Along main corridor between barricades	1105	0.052	0.0	

**Follow-Up Sampling in Areas with Results Above Established Action Levels**

Floor	Location	Retest Time	Total Particulates (mg/m <sup>3</sup> )	TVOC (ppm)	Comments
	N/A				


**Additional Comments**

Date	Floor	Comments
		N/A



**Whitney R. Bishop**  
Industrial Hygienist

*for Whitney Bishop w/permission*



**Christopher P. Williams, CIH**  
Project Manager

**Distribution**

MACTEC	GSA	Jacobs Engineering	DOI
Chris Williams, CIH	James Hodges, CHMM	Bob Pizzano, PM, PE	Gay Bindocci, Ed.D, LEED
	Skip Vaughn, PM	David Altieri, Inspector	
	Pradip Patel, Assistant PM		