

**Daily Engineering Control Verification Sampling
General Services Administration
Department of the Interior Modernization Program
1849 C Street NW, Washington, DC**

Week ending: 7/10/2008

Note 1: TVOC = Total Volatile Organic Compounds, which is the total concentration of any volatile organic compounds that may be present. Volatile organic compounds are organic chemicals that have a high vapor pressure and easily form vapors at normal temperature. While there is currently no Permissible Exposure Limit (PEL) for TVOCs, an action level of 1.3 parts per million (ppm) has been established for this project based on best available research.

Note 2: OSHA Total and Respirable Particulate PEL = 15.0 milligrams per cubic meter of air (mg/m³) for total particulates, 5.0 mg/m³ for respirable particulates.

Friday: 7/04/2008

Floor	Location	Time	Total Particulates (mg/m ³)	TVOC (ppm)	Comments
7	Along main corridor between barricades				
6	Along main corridor between barricades				
5	Along main corridor between barricades		Government Holiday No Testing		
4	Along main corridor between barricades				
3	Along main corridor between barricades				
2	Along main corridor between barricades				
1	Along main corridor between barricades				
B	Along main corridor between barricades				

Monday: 7/07/2008

Floor	Location	Time	Total Particulates (mg/m ³)	TVOC (ppm)	Comments
7	Along main corridor between barricades	1202	0.049	0.0	
6	Along main corridor between barricades	1204	0.029	0.0	
5	Along main corridor between barricades	1206	0.019	0.0	
4	Along main corridor between barricades	1208	0.032	0.0	
3	Along main corridor between barricades	1209	0.040	0.0	
2	Along main corridor between barricades	1211	0.050	0.0	
1	Along main corridor between barricades	1213	0.037	0.0	
B	Along main corridor between barricades	1214	0.066	0.0	

Tuesday: 7/08/2008

Floor	Location	Time	Total Particulates (mg/m ³)	TVOC (ppm)	Comments
7	Along main corridor between barricades	1306	0.040	0.0	
6	Along main corridor between barricades	1308	0.040	0.0	
5	Along main corridor between barricades	1310	0.029	0.0	
4	Along main corridor between barricades	1312	0.039	0.0	
3	Along main corridor between barricades	1314	0.039	0.0	
2	Along main corridor between barricades	1316	0.052	0.0	
1	Along main corridor between barricades	1317	0.036	0.0	
B	Along main corridor between barricades	1419	0.067	0.0	

Wednesday: 7/09/2008

Floor	Location	Time	Total Particulates (mg/m ³)	TVOC (ppm)	Comments
7	Along main corridor between barricades	1218	0.034	0.0	
6	Along main corridor between barricades	1220	0.020	0.0	
5	Along main corridor between barricades	1222	0.012	0.0	
4	Along main corridor between barricades	1224	0.019	0.0	
3	Along main corridor between barricades	1225	0.023	0.0	
2	Along main corridor between barricades	1227	0.038	0.0	
1	Along main corridor between barricades	1229	0.040	0.0	
B	Along main corridor between barricades	1231	0.187	0.0	

Thursday: 7/10/2008


Floor	Location	Time	Total Particulates (mg/m ³)	TVOC (ppm)	Comments
7	Along main corridor between barricades	1032	0.033	0.0	
6	Along main corridor between barricades	1034	0.028	0.0	
5	Along main corridor between barricades	1036	0.016	0.0	
4	Along main corridor between barricades	1038	0.021	0.0	
3	Along main corridor between barricades	1039	0.031	0.0	
2	Along main corridor between barricades	1041	0.039	0.0	
1	Along main corridor between barricades	1043	0.036	0.0	
B	Along main corridor between barricades	1045	0.052	0.0	

Follow-Up Sampling in Areas with Results Above Established Action Levels

Floor	Location	Retest Time	Total Particulates (mg/m ³)	TVOC (ppm)	Comments
	N/A				


Additional Comments

Date	Floor	Comments
		N/A



Whitney R. Bishop
Industrial Hygienist

for Whitney Bishop w/permission



Christopher P. Williams, CIH
Project Manager

Distribution

MACTEC	GSA	Jacobs Engineering	DOI
Chris Williams, CIH	James Hodges, CHMM	Bob Pizzano, PM, PE	Gay Bindocci, Ed.D, LEED
	Skip Vaughn, PM	David Altieri, Inspector	
	Pradip Patel, Assistant PM		