

Daily Engineering Control Verification Sampling
General Services Administration
Department of the Interior Modernization Program
1849 C Street NW, Washington, DC

Week ending: 9/13/2007

Note 1: TVOC = Total Volatile Organic Compounds, which is the total concentration of any volatile organic compounds that may be present. Volatile organic compounds are organic chemicals that have a high vapor pressure and easily form vapors at normal temperature. While there is currently no Permissible Exposure Limit (PEL) for TVOCs, an action level of 1.3 parts per million (ppm) has been established for this project based on best available research.

Note 2: OSHA Total and Respirable Particulate PEL = 15.0 milligrams per cubic meter of air (mg/m³) for total particulates, 5.0 mg/m³ for respirable particulates.

Friday: 9/07/2007

| Floor | Location | Time | Total Particulates (mg/m ³) | TVOC (ppm) | Comments |
|-------|--|------|---|------------|--|
| 7 | Along main corridor between barricades | 1031 | 0.041 | 0.0 | Passed smoke test for negative air pressure at doors |
| 6 | Along main corridor between barricades | 1035 | 0.041 | 0.0 | |
| 5 | Along main corridor between barricades | 1038 | 0.016 | 0.0 | |
| 4 | Along main corridor between barricades | 1040 | 0.067 | 0.0 | |
| 3 | Along main corridor between barricades | 1041 | 0.026 | 0.0 | |
| 2 | Along main corridor between barricades | 1043 | 0.038 | 0.0 | |
| 1 | Along main corridor between barricades | 1044 | 0.030 | 0.0 | Passed smoke test for negative air pressure at doors |
| B | Along main corridor between barricades | 1045 | 0.052 | 0.0 | |
| 7 | Wing 3 rm 7308-7328 | 1033 | 0.055 | 0.0 | |
| 5 | Wing 5 rm 5538-5562 | 1047 | 0.017 | 0.0 | |

Monday: 9/10/2007

| Floor | Location | Time | Total Particulates (mg/m ³) | TVOC (ppm) | Comments |
|-------|--|------|---|------------|--|
| 7 | Along main corridor between barricades | 1414 | 0.056 | 0.0 | Passed smoke test for negative air pressure at doors |
| 6 | Along main corridor between barricades | 1418 | 0.045 | 0.0 | |
| 5 | Along main corridor between barricades | 1420 | 0.039 | 0.0 | |
| 4 | Along main corridor between barricades | 1423 | 0.044 | 0.0 | |
| 3 | Along main corridor between barricades | 1425 | 0.027 | 0.0 | |
| 2 | Along main corridor between barricades | 1427 | 0.056 | 0.0 | |
| 1 | Along main corridor between barricades | 1428 | 0.111 | 0.0 | Passed smoke test for negative air pressure at doors |
| B | Along main corridor between barricades | 1429 | 0.081 | 0.0 | |
| 4 | Wing 3 rm 4310-4329 | 1421 | 0.057 | 0.0 | |
| 3 | Wing 5 rm 3538-3560 | 1424 | 0.028 | 0.0 | |

Tuesday: 9/11/2007

| Floor | Location | Time | Total Particulates (mg/m ³) | TVOC (ppm) | Comments |
|-------|--|------|---|------------|--|
| 7 | Along main corridor between barricades | 1244 | 0.086 | 0.0 | Passed smoke test for negative air pressure at doors |
| 6 | Along main corridor between barricades | 1247 | 0.050 | 0.0 | |
| 5 | Along main corridor between barricades | 1249 | 0.033 | 0.0 | |
| 4 | Along main corridor between barricades | 1251 | 0.066 | 0.0 | |
| 3 | Along main corridor between barricades | 1252 | 0.045 | 0.0 | |
| 2 | Along main corridor between barricades | 1254 | 0.057 | 0.0 | |
| 1 | Along main corridor between barricades | 1258 | 0.080 | 0.0 | Passed smoke test for negative air pressure at doors |
| B | Along main corridor between barricades | 1259 | 0.058 | 0.0 | |
| 6 | Wing 3 rm 6310-6331 | 1246 | 0.044 | 0.0 | |
| 1 | Wing 5 rm 1540-1559 | 1257 | 0.017 | 0.0 | |

Wednesday: 9/12/2007

| Floor | Location | Time | Total Particulates (mg/m ³) | TVOC (ppm) | Comments |
|-------|--|------|---|------------|--|
| 7 | Along main corridor between barricades | 1304 | 0.035 | 0.0 | Passed smoke test for negative air pressure at doors |
| 6 | Along main corridor between barricades | 1306 | 0.022 | 0.0 | |
| 5 | Along main corridor between barricades | 1308 | 0.009 | 0.0 | |
| 4 | Along main corridor between barricades | 1312 | 0.019 | 0.0 | |
| 3 | Along main corridor between barricades | 1315 | 0.014 | 0.0 | |
| 2 | Along main corridor between barricades | 1317 | 0.027 | 0.0 | |
| 1 | Along main corridor between barricades | 1318 | 0.069 | 0.0 | Passed smoke test for negative air pressure at doors |
| B | Along main corridor between barricades | 1320 | 0.043 | 0.0 | |
| 5 | Wing 3 rm 5309-5331 | 1310 | 0.028 | 0.0 | |
| 4 | Wing 5 rm 4538-4561 | 1314 | 0.008 | 0.0 | |

Thursday: 9/13/2007


| Floor | Location | Time | Total Particulates (mg/m ³) | TVOC (ppm) | Comments |
|-------|--|------|---|------------|--|
| 7 | Along main corridor between barricades | 1144 | 0.036 | 0.0 | Passed smoke test for negative air pressure at doors |
| 6 | Along main corridor between barricades | 1146 | 0.024 | 0.0 | |
| 5 | Along main corridor between barricades | 1148 | 0.014 | 0.0 | |
| 4 | Along main corridor between barricades | 1150 | 0.030 | 0.0 | |
| 3 | Along main corridor between barricades | 1151 | 0.035 | 0.0 | |
| 2 | Along main corridor between barricades | 1155 | 0.025 | 0.0 | |
| 1 | Along main corridor between barricades | 1156 | 0.089 | 0.0 | Passed smoke test for negative air pressure at doors |
| B | Along main corridor between barricades | 1200 | 0.071 | 0.0 | |
| 2 | Wing 3 rm 2340-2357 | 1153 | 0.030 | 0.0 | |
| 1 | Wing 3 rm 1312-1329 | 1158 | 0.041 | 0.0 | |


Follow-Up Sampling in Areas with Results Above Established Action Levels

| Floor | Location | Retest Time | Total Particulates (mg/m ³) | TVOC (ppm) | Comments |
|-------|----------|-------------|---|------------|----------|
| | N/A | | | | |
| | | | | | |
| | | | | | |
| | | | | | |

Additional Comments

| Date | Floor | Comments |
|------|-------|----------|
| | | |
| | | |
| | | |
| | | |


 Whitney R. Bishop
 Industrial Hygienist


 Christopher P. Williams, CIH
 Principal Safety & IH Specialist

Distribution

| MACTEC | GSA | Jacobs Engineering | DOI |
|---------------------|----------------------------|--------------------------|--------------------------|
| Chris Williams, CIH | James Hodges, CHMM | Bob Pizzano, PM, PE | Gay Bindocci, Ed.D, LEED |
| | Skip Vaughn, PM | David Altieri, Inspector | |
| | Pradip Patel, Assistant PM | | |