

**Daily Engineering Control Verification Sampling
General Services Administration
Department of the Interior Modernization Program
1849 C Street NW, Washington, DC**

Week ending: 11/29/2007

Note 1: TVOC = Total Volatile Organic Compounds, which is the total concentration of any volatile organic compounds that may be present. Volatile organic compounds are organic chemicals that have a high vapor pressure and easily form vapors at normal temperature. While there is currently no Permissible Exposure Limit (PEL) for TVOCs, an action level of 1.3 parts per million (ppm) has been established for this project based on best available research.

Note 2: OSHA Total and Respirable Particulate PEL = 15.0 milligrams per cubic meter of air (mg/m³) for total particulates, 5.0 mg/m³ for respirable particulates.

Friday: 11/23/2007

Floor	Location	Time	Total Particulates (mg/m ³)	TVOC (ppm)	Comments
7	Along main corridor between barricades				
6	Along main corridor between barricades				
5	Along main corridor between barricades				
4	Along main corridor between barricades				
3	Along main corridor between barricades				
2	Along main corridor between barricades				
1	Along main corridor between barricades				
B	Along main corridor between barricades				
<div style="border: 1px solid black; padding: 20px; width: fit-content; margin: auto;"> <h1 style="margin: 0;">Holiday</h1> <h2 style="margin: 0;">For IH</h2> <h3 style="margin: 0;">No testing</h3> </div>					

Monday: 11/26/2007

Floor	Location	Time	Total Particulates (mg/m ³)	TVOC (ppm)	Comments
7	Along main corridor between barricades	1436	0.021	0.0	
6	Along main corridor between barricades	1438	0.016	0.0	
5	Along main corridor between barricades	1442	0.016	0.0	
4	Along main corridor between barricades	1444	0.014	0.0	
3	Along main corridor between barricades	1446	0.016	0.0	
2	Along main corridor between barricades	1450	0.017	0.0	
1	Along main corridor between barricades	1452	0.020	0.0	Passed smoke test for negative air pressure at doors
B	Along main corridor between barricades	1454	0.028	0.0	
6	Wing 5 6510-6531	1440	0.012	0.0	
2	Wing 3 2340-2357	1449	0.014	0.0	

Tuesday: 11/27/2007

Floor	Location	Time	Total Particulates (mg/m ³)	TVOC (ppm)	Comments
7	Along main corridor between barricades	1324	0.046	0.0	
6	Along main corridor between barricades	1327	0.031	0.0	
5	Along main corridor between barricades	1331	0.012	0.0	
4	Along main corridor between barricades	1333	0.024	0.0	
3	Along main corridor between barricades	1336	0.018	0.0	
2	Along main corridor between barricades	1338	0.027	0.0	
1	Along main corridor between barricades	1339	0.032	0.0	Passed smoke test for negative air pressure at doors
B	Along main corridor between barricades	1341	0.031	0.0	
5	Wing 5 rm 5509-5531	1329	0.006	0.0	
4	Wing 5 rm 4538-4561	1334	0.016	0.0	

Wednesday: 11/28/2007

Floor	Location	Time	Total Particulates (mg/m ³)	TVOC (ppm)	Comments
7	Along main corridor between barricades	1226	0.005	0.0	
6	Along main corridor between barricades	1229	0.004	0.0	
5	Along main corridor between barricades	1230	0.002	0.0	
4	Along main corridor between barricades	1232	0.005	0.0	
3	Along main corridor between barricades	1233	0.042	0.0	
2	Along main corridor between barricades	1237	0.007	0.0	
1	Along main corridor between barricades	1238	0.023	0.0	Passed smoke test for negative air pressure at doors
B	Along main corridor between barricades	1239	0.036	0.0	
7	Wing 3 rm 7308-7328	1227	0.018	0.0	
3	Wing 3 rm 3306-3331	1236	0.009	0.0	

Thursday: 11/29/2007


Floor	Location	Time	Total Particulates (mg/m ³)	TVOC (ppm)	Comments
7	Along main corridor between barricades	1137	0.023	0.0	
6	Along main corridor between barricades	1139	0.019	0.0	
5	Along main corridor between barricades	1141	0.016	0.0	
4	Along main corridor between barricades	1145	0.018	0.0	
3	Along main corridor between barricades	1147	0.016	0.0	
2	Along main corridor between barricades	1148	0.026	0.0	
1	Along main corridor between barricades	1150	0.029	0.0	Passed smoke test for negative air pressure at doors
B	Along main corridor between barricades	1154	0.031	0.0	
5	Wing 3 rm 5309-5331	1143	0.019	0.0	
1	Wing 3 rm 1340-1366	1152	0.015	0.0	


Follow-Up Sampling in Areas with Results Above Established Action Levels

Floor	Location	Retest Time	Total Particulates (mg/m ³)	TVOC (ppm)	Comments
	N/A				

Additional Comments

Date	Floor	Comments


 Whitney R. Bishop
 Industrial Hygienist


 Christopher P. Williams, CIH
 Principal Safety & IH Specialist
with permission by KSBC

Distribution

MACTEC	GSA	Jacobs Engineering	DOI
Chris Williams, CIH	James Hodges, CHMM	Bob Pizzano, PM, PE	Gay Bindocci, Ed.D, LEED
	Skip Vaughn, PM	David Altieri, Inspector	
	Pradip Patel, Assistant PM		