

**Daily Engineering Control Verification Sampling
General Services Administration
Department of the Interior Modernization Program
1849 C Street NW, Washington, DC**

Week ending: 11/15/2007

Note 1: TVOC = Total Volatile Organic Compounds, which is the total concentration of any volatile organic compounds that may be present. Volatile organic compounds are organic chemicals that have a high vapor pressure and easily form vapors at normal temperature. While there is currently no Permissible Exposure Limit (PEL) for TVOCs, an action level of 1.3 parts per million (ppm) has been established for this project based on best available research.

Note 2: OSHA Total and Respirable Particulate PEL = 15.0 milligrams per cubic meter of air (mg/m³) for total particulates, 5.0 mg/m³ for respirable particulates.

Friday: 11/09/2007

Floor	Location	Time	Total Particulates (mg/m ³)	TVOC (ppm)	Comments
7	Along main corridor between barricades	1229	0.018	0.0	
6	Along main corridor between barricades	1231	0.017	0.0	
5	Along main corridor between barricades	1232	0.016	0.0	
4	Along main corridor between barricades	1235	0.009	0.0	
3	Along main corridor between barricades	1238	0.010	0.0	
2	Along main corridor between barricades	1239	0.010	0.0	
1	Along main corridor between barricades	1240	0.025	0.0	Passed smoke test for negative air pressure at doors
B	Along main corridor between barricades	1241	0.132	0.0	
5	Wing 3 rm 5309-5331	1234	0.011	0.0	
3	Wing 5 rm 3538-3560	1237	0.029	0.0	

Monday: 11/12/2007

Floor	Location	Time	Total Particulates (mg/m ³)	TVOC (ppm)	Comments
7	Along main corridor between barricades				
6	Along main corridor between barricades				
5	Along main corridor between barricades				
4	Along main corridor between barricades				
3	Along main corridor between barricades				
2	Along main corridor between barricades				
1	Along main corridor between barricades				
B	Along main corridor between barricades				

Holiday
No testing

Tuesday: 11/13/2007

Floor	Location	Time	Total Particulates (mg/m ³)	TVOC (ppm)	Comments
7	Along main corridor between barricades	1207	0.031	0.0	
6	Along main corridor between barricades	1210	0.030	0.0	
5	Along main corridor between barricades	1211	0.025	0.0	
4	Along main corridor between barricades	1213	0.029	0.0	
3	Along main corridor between barricades	1214	0.025	0.0	
2	Along main corridor between barricades	1217	0.035	0.0	
1	Along main corridor between barricades	1218	0.043	0.0	Passed smoke test for negative air pressure at doors
B	Along main corridor between barricades	1220	0.048	0.0	
7	Wing 3 rm 7339-7360	1209	0.021	0.0	
2	Wing 3 rm 2312-2329	1216	0.030	0.0	

Wednesday: 11/14/2007

Floor	Location	Time	Total Particulates (mg/m ³)	TVOC (ppm)	Comments
7	Along main corridor between barricades	1352	0.034	0.0	
6	Along main corridor between barricades	1355	0.039	0.0	
5	Along main corridor between barricades	1358	0.027	0.0	
4	Along main corridor between barricades	1400	0.029	0.0	
3	Along main corridor between barricades	1405	0.052	0.0	
2	Along main corridor between barricades	1407	0.046	0.0	
1	Along main corridor between barricades	1408	0.092	0.0	Passed smoke test for negative air pressure at doors
B	Along main corridor between barricades	1410	0.050	0.0	
6	Wing 5 rm 6510-6531	1356	0.026	0.0	
4	Wing 5 rm 4508-4531	1402	0.023	0.0	

Thursday: 11/15/2007

Floor	Location	Time	Total Particulates (mg/m ³)	TVOC (ppm)	Comments
7	Along main corridor between barricades	1231	0.003	0.0	
6	Along main corridor between barricades	1233	0.006	0.0	
5	Along main corridor between barricades	1236	0.003	0.0	
4	Along main corridor between barricades	1238	0.004	0.0	
3	Along main corridor between barricades	1240	0.007	0.0	
2	Along main corridor between barricades	1241	0.006	0.0	
1	Along main corridor between barricades	1243	0.015	0.0	Passed smoke test for negative air pressure at doors
B	Along main corridor between barricades	1247	0.020	0.0	
5	Wing 5 rm 5538-5562	1235	0.001	0.0	
1	Wing 3 rm 1340-1366	1245	0.004	0.0	


Follow-Up Sampling in Areas with Results Above Established Action Levels

Floor	Location	Retest Time	Total Particulates (mg/m ³)	TVOC (ppm)	Comments
	N/A				

Additional Comments

Date	Floor	Comments


 Whitney R. Bishop
 Industrial Hygienist


 Christopher P. Williams, CIH
 Project Manager

Distribution

MACTEC	GSA	Jacobs Engineering	DOI
Chris Williams, CIH	James Hodges, CHMM	Bob Pizzano, PM, PE	Gay Bindocci, Ed.D, LEED
	Skip Vaughn, PM	David Altieri, Inspector	
	Pradip Patel, Assistant PM		