

**Daily Engineering Control Verification Sampling
General Services Administration
Department of the Interior Modernization Program
1849 C Street NW, Washington, DC**

Week ending: 11/22/2007

Note 1: TVOC = Total Volatile Organic Compounds, which is the total concentration of any volatile organic compounds that may be present. Volatile organic compounds are organic chemicals that have a high vapor pressure and easily form vapors at normal temperature. While there is currently no Permissible Exposure Limit (PEL) for TVOCs, an action level of 1.3 parts per million (ppm) has been established for this project based on best available research.

Note 2: OSHA Total and Respirable Particulate PEL = 15.0 milligrams per cubic meter of air (mg/m³) for total particulates, 5.0 mg/m³ for respirable particulates.

Friday: 11/16/2007

Floor	Location	Time	Total Particulates (mg/m ³)	TVOC (ppm)	Comments
7	Along main corridor between barricades	1133	0.003	0.0	
6	Along main corridor between barricades	1136	0.003	0.0	
5	Along main corridor between barricades	1138	0.002	0.0	
4	Along main corridor between barricades	1140	0.003	0.0	
3	Along main corridor between barricades	1143	0.004	0.0	
2	Along main corridor between barricades	1145	0.002	0.0	
1	Along main corridor between barricades	1147	0.034	0.0	Passed smoke test for negative air pressure at doors
B	Along main corridor between barricades	1148	0.020	0.0	
6	Wing 3 rm 6319-6362	1135	0.016	0.0	
3	Wing 5 rm 3509-3531	1142	0.000	0.0	

Monday: 11/19/2007

Floor	Location	Time	Total Particulates (mg/m ³)	TVOC (ppm)	Comments
7	Along main corridor between barricades	1432	0.017	0.0	
6	Along main corridor between barricades	1434	0.011	0.0	
5	Along main corridor between barricades	1436	0.013	0.0	
4	Along main corridor between barricades	1438	0.013	0.0	
3	Along main corridor between barricades	1440	0.013	0.0	
2	Along main corridor between barricades	1443	0.017	0.0	
1	Along main corridor between barricades	1445	0.021	0.0	Passed smoke test for negative air pressure at doors
B	Along main corridor between barricades	1447	0.027	0.0	
7	Wing 5 7538-7559	1430	0.009	0.0	
2	Wing 3 2310-2329	1442	0.019	0.0	

Tuesday: 11/20/2007

Floor	Location	Time	Total Particulates (mg/m ³)	TVOC (ppm)	Comments
7	Along main corridor between barricades	1208	0.037	0.0	
6	Along main corridor between barricades	1210	0.022	0.0	
5	Along main corridor between barricades	1215	0.024	0.0	
4	Along main corridor between barricades	1217	0.021	0.0	
3	Along main corridor between barricades	1219	0.025	0.0	
2	Along main corridor between barricades	1221	0.038	0.0	
1	Along main corridor between barricades	1224	0.051	0.0	Passed smoke test for negative air pressure at doors
B	Along main corridor between barricades	1226	0.035	0.0	
5	Wing 5 rm 5509-5531	1214	0.015	0.0	
1	Wing 5 rm 1540-1559	1223	0.019	0.0	

Wednesday: 11/21/2007

Floor	Location	Time	Total Particulates (mg/m ³)	TVOC (ppm)	Comments
7	Along main corridor between barricades	1103	0.045	0.0	
6	Along main corridor between barricades	1105	0.041	0.0	
5	Along main corridor between barricades	1107	0.041	0.0	
4	Along main corridor between barricades	1110	0.038	0.0	
3	Along main corridor between barricades	1112	0.062	0.0	
2	Along main corridor between barricades	1113	0.042	0.0	
1	Along main corridor between barricades	1117	0.104	0.0	Passed smoke test for negative air pressure at doors
B	Along main corridor between barricades	1118	0.069	0.0	
4	Wing 3 rm 4310-4329	1109	0.043	0.0	
2	Wing 5 rm 2538-2563	1115	0.024	0.0	

Thursday: 11/22/2007

Floor	Location	Time	Total Particulates (mg/m ³)	TVOC (ppm)	Comments
7	Along main corridor between barricades				
6	Along main corridor between barricades				
5	Along main corridor between barricades				
4	Along main corridor between barricades				
3	Along main corridor between barricades				
2	Along main corridor between barricades				
1	Along main corridor between barricades				
B	Along main corridor between barricades				


Holiday
No testing

Follow-Up Sampling in Areas with Results Above Established Action Levels

Floor	Location	Retest Time	Total Particulates (mg/m ³)	TVOC (ppm)	Comments
	N/A				

Additional Comments

Date	Floor	Comments


 Whitney R. Bishop
 Industrial Hygienist


 Christopher P. Williams, CIH
 Project Manager

Distribution

MACTEC	GSA	Jacobs Engineering	DOI
Chris Williams, CIH	James Hodges, CHMM	Bob Pizzano, PM, PE	Gay Bindocci, Ed.D, LEED
	Skip Vaughn, PM	David Altieri, Inspector	
	Pradip Patel, Assistant PM		