

**Daily Engineering Control Verification Sampling
General Services Administration
Department of the Interior Modernization Program
1849 C Street NW, Washington, DC**

Week ending: 12/27/2007

Note 1: TVOC = Total Volatile Organic Compounds, which is the total concentration of any volatile organic compounds that may be present. Volatile organic compounds are organic chemicals that have a high vapor pressure and easily form vapors at normal temperature. While there is currently no Permissible Exposure Limit (PEL) for TVOCs, an action level of 1.3 parts per million (ppm) has been established for this project based on best available research.

Note 2: OSHA Total and Respirable Particulate PEL = 15.0 milligrams per cubic meter of air (mg/m³) for total particulates, 5.0 mg/m³ for respirable particulates.

Friday: 12/21/2007

Floor	Location	Time	Total Particulates (mg/m ³)	TVOC (ppm)	Comments
7	Along main corridor between barricades	930	0.028	0.0	
6	Along main corridor between barricades	931	0.026	0.0	
5	Along main corridor between barricades	933	0.012	0.0	
4	Along main corridor between barricades	936	0.039	0.0	
3	Along main corridor between barricades	940	0.030	0.0	
2	Along main corridor between barricades	941	0.028	0.0	
1	Along main corridor between barricades	943	0.042	0.0	Passed smoke test for negative air pressure at doors
B	Along main corridor between barricades	944	0.036	0.0	
5	Wing 3 rm 5309-5331	935	0.029	0.0	
3	Wing 5 rm 3538-3560	938	0.021	0.0	

Monday: 12/24/2007

Floor	Location	Time	Total Particulates (mg/m ³)	TVOC (ppm)	Comments
7	Along main corridor between barricades				
6	Along main corridor between barricades				
5	Along main corridor between barricades				
4	Along main corridor between barricades				
3	Along main corridor between barricades				
2	Along main corridor between barricades				
1	Along main corridor between barricades				
B	Along main corridor between barricades				

Holiday
No testing

Tuesday: 12/25/2007

Floor	Location	Time	Total Particulates (mg/m ³)	TVOC (ppm)	Comments
7	Along main corridor between barricades				<div style="border: 1px solid black; padding: 20px; font-size: 2em;"> Holiday No testing </div>
6	Along main corridor between barricades				
5	Along main corridor between barricades				
4	Along main corridor between barricades				
3	Along main corridor between barricades				
2	Along main corridor between barricades				
1	Along main corridor between barricades				
B	Along main corridor between barricades				

Wednesday: 12/26/2007

Floor	Location	Time	Total Particulates (mg/m ³)	TVOC (ppm)	Comments
7	Along main corridor between barricades				<div style="border: 1px solid black; padding: 20px; font-size: 2em;"> IH on vacation No testing </div>
6	Along main corridor between barricades				
5	Along main corridor between barricades				
4	Along main corridor between barricades				
3	Along main corridor between barricades				
2	Along main corridor between barricades				
1	Along main corridor between barricades				
B	Along main corridor between barricades				

Thursday: 12/27/2007


Floor	Location	Time	Total Particulates (mg/m ³)	TVOC (ppm)	Comments
7	Along main corridor between barricades	1322	0.011	0.0	
6	Along main corridor between barricades	1324	0.010	0.0	
5	Along main corridor between barricades	1326	0.008	0.0	
4	Along main corridor between barricades	1328	0.017	0.0	
3	Along main corridor between barricades	1329	0.013	0.0	
2	Along main corridor between barricades	1333	0.019	0.0	
1	Along main corridor between barricades	1334	0.025	0.0	Passed smoke test for negative air pressure at doors
B	Along main corridor between barricades	1336	0.019	0.0	
7	Wing 5 rm 7508-7530	1320	0.008	0.0	
2	Wing 3 rm 2340-2357	1332	0.012	0.0	


Follow-Up Sampling in Areas with Results Above Established Action Levels

Floor	Location	Retest Time	Total Particulates (mg/m ³)	TVOC (ppm)	Comments
	N/A				

Additional Comments

Date	Floor	Comments


 Whitney R. Bishop
 Industrial Hygienist


 Christopher P. Williams, CIH
 Project Manager

Distribution

MACTEC	GSA	Jacobs Engineering	DOI
Chris Williams, CIH	James Hodges, CHMM	Bob Pizzano, PM, PE	Gay Bindocci, Ed.D, LEED
	Skip Vaughn, PM	David Altieri, Inspector	
	Pradip Patel, Assistant PM		