

**Daily Engineering Control Verification Sampling
General Services Administration
Department of the Interior Modernization Program
1849 C Street NW, Washington, DC**

Week ending : 3/06/2008

Note 1: TVOC = Total Volatile Organic Compounds, which is the total concentration of any volatile organic compounds that may be present. Volatile organic compounds are organic chemicals that have a high vapor pressure and easily form vapors at normal temperature. While there is currently no Permissible Exposure Limit (PEL) for TVOCs, an action level of 1.3 parts per million (ppm) has been established for this project based on best available research.

Note 2: OSHA Total and Respirable Particulate PEL = 15.0 milligrams per cubic meter of air (mg/m³) for total particulates, 5.0 mg/m³ for respirable particulates.

Friday: 2/29/2008

Floor	Location	Time	Total Particulates (mg/m ³)	TVOC (ppm)	Comments
7	Along main corridor between barricades	1131	0.011	0.0	
6	Along main corridor between barricades	1133	0.017	0.0	
5	Along main corridor between barricades	1135	0.008	0.0	
4	Along main corridor between barricades	1139	0.012	0.0	
3	Along main corridor between barricades	1141	0.011	0.0	
2	Along main corridor between barricades	1143	0.009	0.0	
1	Along main corridor between barricades	1145	0.060	0.0	Passed smoke test for negative air pressure at doors
B	Along main corridor between barricades	1146	0.018	0.0	
5	Wing 3 rm 5339-5361	1137	0.013	0.0	

Monday: 3/03/2008

Floor	Location	Time	Total Particulates (mg/m ³)	TVOC (ppm)	Comments
7	Along main corridor between barricades	1031	0.013	0.0	
6	Along main corridor between barricades	1033	0.017	0.0	
5	Along main corridor between barricades	1036	0.007	0.0	
4	Along main corridor between barricades	1038	0.016	0.0	
3	Along main corridor between barricades	1042	0.012	0.0	
2	Along main corridor between barricades	1044	0.011	0.0	
1	Along main corridor between barricades	1045	0.045	0.0	Passed smoke test for negative air pressure at doors
B	Along main corridor between barricades	1047	0.029	0.0	
3	Wing 3 rm 3509-3531	1040	0.008	0.0	

Tuesday: 3/04/2008

Floor	Location	Time	Total Particulates (mg/m ³)	TVOC (ppm)	Comments
7	Along main corridor between barricades	1437	0.016	0.0	
6	Along main corridor between barricades	1439	0.012	0.0	
5	Along main corridor between barricades	1441	0.021	0.0	
4	Along main corridor between barricades	1443	0.014	0.0	
3	Along main corridor between barricades	1445	0.015	0.0	
2	Along main corridor between barricades	1449	0.012	0.0	
1	Along main corridor between barricades	1450	0.026	0.0	Passed smoke test for negative air pressure at doors
B	Along main corridor between barricades	1452	0.024	0.0	
2	Wing 3 rm 2340-2357	1447	0.013	0.0	

Wednesday: 3/05/2008

Floor	Location	Time	Total Particulates (mg/m ³)	TVOC (ppm)	Comments
7	Along main corridor between barricades	1236	0.005	0.0	
6	Along main corridor between barricades	1239	0.021	0.0	
5	Along main corridor between barricades	1241	0.030	0.0	
4	Along main corridor between barricades	1243	0.006	0.0	
3	Along main corridor between barricades	1247	0.005	0.0	
2	Along main corridor between barricades	1249	0.002	0.0	
1	Along main corridor between barricades	1251	0.028	0.0	Passed smoke test for negative air pressure at doors
B	Along main corridor between barricades	1253	0.170	0.0	
4	Wing 5 rm 4508-4531	1245	0.009	0.0	

Thursday: 3/06/2008

Floor	Location	Time	Total Particulates (mg/m ³)	TVOC (ppm)	Comments
7	Along main corridor between barricades	1428	0.018	0.0	
6	Along main corridor between barricades	1432	0.024	0.0	
5	Along main corridor between barricades	1434	0.013	0.0	
4	Along main corridor between barricades	1436	0.022	0.0	
3	Along main corridor between barricades	1438	0.015	0.0	
2	Along main corridor between barricades	1440	0.014	0.0	
1	Along main corridor between barricades	1442	0.044	0.0	Passed smoke test for negative air pressure at doors
B	Along main corridor between barricades	1444	0.031	0.0	
7	Wing 3 rm 7339-7360	1430	0.014	0.0	

Follow-Up Sampling in Areas with Results Above Established Action Levels

Floor	Location	Retest Time	Total Particulates (mg/m ³)	TVOC (ppm)	Comments
	N/A				

Additional Comments

Date	Floor	Comments

Whitney R. Bishop
 Whitney R. Bishop
 Industrial Hygienist

Chris P. Williams
 Christopher P. Williams, CIH
 Project Manager

Distribution

MACTEC	GSA	Jacobs Engineering	DOI
Chris Williams, CIH	James Hodges, CHMM	Bob Pizzano, PM, PE	Gay Bindocci, Ed.D, LEED
	Skip Vaughn, PM	David Altieri, Inspector	
	Pradip Patel, Assistant PM		