

**Daily Engineering Control Verification Sampling
General Services Administration
Department of the Interior Modernization Program
1849 C Street NW, Washington, DC**

Week ending : 3/13/2008

Note 1: TVOC = Total Volatile Organic Compounds, which is the total concentration of any volatile organic compounds that may be present. Volatile organic compounds are organic chemicals that have a high vapor pressure and easily form vapors at normal temperature. While there is currently no Permissible Exposure Limit (PEL) for TVOCs, an action level of 1.3 parts per million (ppm) has been established for this project based on best available research.

Note 2: OSHA Total and Respirable Particulate PEL = 15.0 milligrams per cubic meter of air (mg/m³) for total particulates, 5.0 mg/m³ for respirable particulates.

Friday: 3/07/2008

Floor	Location	Time	Total Particulates (mg/m ³)	TVOC (ppm)	Comments
7	Along main corridor between barricades	1119	0.023	0.0	
6	Along main corridor between barricades	1121	0.021	0.0	
5	Along main corridor between barricades	1123	0.017	0.0	
4	Along main corridor between barricades	1125	0.018	0.0	
3	Along main corridor between barricades	1127	0.015	0.0	
2	Along main corridor between barricades	1129	0.018	0.0	
1	Along main corridor between barricades	1131	0.040	0.0	Passed smoke test for negative air pressure at doors
B	Along main corridor between barricades	1137	0.035	0.0	
1	Wing 3 rm 1340-1366	1135	0.042	0.0	

Monday: 3/10/2008

Floor	Location	Time	Total Particulates (mg/m ³)	TVOC (ppm)	Comments
7	Along main corridor between barricades	1301	0.013	0.0	
6	Along main corridor between barricades	1305	0.041	0.0	
5	Along main corridor between barricades	1307	0.008	0.0	
4	Along main corridor between barricades	1309	0.013	0.0	
3	Along main corridor between barricades	1311	0.013	0.0	
2	Along main corridor between barricades	1313	0.010	0.0	
1	Along main corridor between barricades	1315	0.037	0.0	Passed smoke test for negative air pressure at doors
B	Along main corridor between barricades	1317	0.087	0.0	
6	Wing 3 rm 6339-6362	1303	0.015	0.0	

Tuesday: 3/11/2008

Floor	Location	Time	Total Particulates (mg/m ³)	TVOC (ppm)	Comments
7	Along main corridor between barricades	1436	0.025	0.0	
6	Along main corridor between barricades	1438	0.071	0.0	
5	Along main corridor between barricades	1440	0.027	0.0	
4	Along main corridor between barricades	1442	0.031	0.0	
3	Along main corridor between barricades	1446	0.021	0.0	
2	Along main corridor between barricades	1448	0.024	0.0	
1	Along main corridor between barricades	1450	0.043	0.0	Passed smoke test for negative air pressure at doors
B	Along main corridor between barricades	1451	0.053	0.0	
4	Wing 5 rm4538-4561	1444	0.024	0.0	

Wednesday: 3/12/2008

Floor	Location	Time	Total Particulates (mg/m ³)	TVOC (ppm)	Comments
7	Along main corridor between barricades	1129	0.023	0.0	
6	Along main corridor between barricades	1131	0.059	0.0	
5	Along main corridor between barricades	1133	0.037	0.0	
4	Along main corridor between barricades	1135	0.017	0.0	
3	Along main corridor between barricades	1137	0.019	0.0	
2	Along main corridor between barricades	1141	0.019	0.0	
1	Along main corridor between barricades	1143	0.037	0.0	Passed smoke test for negative air pressure at doors
B	Along main corridor between barricades	1145	0.108	0.0	
2	Wing 3 rm 2312-2329	1139	0.043	0.0	

Thursday: 3/13/2008

Floor	Location	Time	Total Particulates (mg/m ³)	TVOC (ppm)	Comments
7	Along main corridor between barricades	1335	0.031	0.0	
6	Along main corridor between barricades	1337	0.080	0.0	
5	Along main corridor between barricades	1339	0.015	0.0	
4	Along main corridor between barricades	1343	0.013	0.0	
3	Along main corridor between barricades	1345	0.023	0.0	
2	Along main corridor between barricades	1347	0.021	0.0	
1	Along main corridor between barricades	1349	0.033	0.0	Passed smoke test for negative air pressure at doors
B	Along main corridor between barricades	1351	0.063	0.0	
5	Wing 5 rm5509-5531	1341	0.008	0.0	


Follow-Up Sampling in Areas with Results Above Established Action Levels

Floor	Location	Retest Time	Total Particulates (mg/m ³)	TVOC (ppm)	Comments
	N/A				

Additional Comments

Date	Floor	Comments


 Whitney R. Bishop
 Industrial Hygienist


 Christopher P. Williams, CIH
 Project Manager

Distribution

MACTEC	GSA	Jacobs Engineering	DOI
Chris Williams, CIH	James Hodges, CHMM	Bob Pizzano, PM, PE	Gay Bindocci, Ed.D, LEED
	Skip Vaughn, PM	David Altieri, Inspector	
	Pradip Patel, Assistant PM		